


NSF COMPLIANT

NPS	DN	A	B	C	D	E	F	G	n x Ø H	ISO5211	L	M	P	Q	X	Y
2"	50	52.6	142	32	80	96	70	90	4x Ø 10	F7	43	9	120.65	4-5/8UNC	251.2	174
2.5"	65	64.4	155	32	89	116	70	90	4x Ø 10	F7	46	9	139.7	4-5/8UNC	251.2	187
3"	80	78.9	161	32	95	132	70	90	4x Ø 10	F7	46	9	152.4	4-5/8UNC	251.2	193
4"	100	104.1	180	32	114	152	70	90	4x Ø 10	F7	52	11	190.5	8-5/8UNC	251.2	212
5"	125	123.4	193	32	127	182	70	90	4x Ø 10	F7	56	14	215.9	8-3/4UNC	251.2	225
6"	150	155.96	205	32	139	205	70	90	4x Ø 10	F7	56	14	241.3	8-3/4UNC	251.2	237

10	PREVENTOR	Spring steel
9	WASHER	SS
8	HALF RING	SS
7	O-Ring	EPDM
6	Bush	Nylon
5	LowerShaft	SS420
4	UpperShaft	SS420
3	Seat	EPDM
2	Disc	CF8M
1	Body	DUCTILE IRON
NO.	PARTS	DESCRIPTION

SIZE:	PRESSURE: PN16	WEIGHT:	SCALE:
DRFTER:	SPECIFICATION:	TITLE: 2" TO 6" LT STYLE BUTTERFLY	
CHECKED BY:	MAPLEF	DRAWING NO.:	DATE:





*This certifies that*

**TIANJIN GREATWALL FLOW VALVE CO. LTD.**

---

*has had the undermentioned product(s) examined, tested and certified as being of an appropriate quality and standard as required in the Water Supply (Water Fittings) Regulations and Scottish Water Byelaws, subject to scheme requirements being met when installed.*

*Model Numbers*

**D71X-10/16-701/705-00 & D71X-10/16-702/706-00 BUTTERFLY VALVES:  
DN32-400**

*The certificate by itself is not evidence of a valid WRAS Approval. Confirmation of the current status of an approval must be obtained from the WRAS Approvals Directory ([www.wras.co.uk/directory](http://www.wras.co.uk/directory))*

---

*The product so mentioned will be valid until the end of:*

**March 2026**

*Certificate No.*

**2103018**

A handwritten signature in blue ink, appearing to read 'Ian Hughes', written over a horizontal line.

Ian Hughes,  
WRAS Approvals Manager